

Office of the District Fire Officer  
Karnataka State Fire  
and Emergency Services  
Khanapur Road, Belagavi-590001



Phone : 0831-2429441  
E-Mail : dfobgv@gmail.com

C.NO/300/NOC/DFO/BELAGAVI/2022-23

Date : 27-03-2023

To,  
The President  
Shri Shirdi Sai  
Shikshan Samsthe,  
Kokatnur Road, Saigiri, Athani,  
Athani Taluk, Belagavi District.

Sir,

Sub: Issue of “NOC” Shri Shirdi Sai Shikshan Samsthe’s, Institution, Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District.

Ref:- 1) C.NO/300/ADV/DFO/BELAGAVI/2022 Date: 28-11-2022.

2) Applicant Request Letter Dated : 23-03-2023.

3) C.No.01/FSO/Athani/2023 Date : 25-03-2023.

\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*

With reference to the subject above cited, the premises of **Shri Shirdi Sai Shikshan Samsthe’s, Institution**, building consisting with Ground & 1<sup>st</sup> floor situated at **Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District** was inspected by Fire Station Officer Athani on 24-03-2023 with respect to fire Prevention, Fire Fighting & Evacuation point of view for the purpose of issuing NOC and has submitted the details as under.

#### ANNEXURE-1

(Up to 14.99 mtrs. In height) **GROUP-B Educational Buildings**

*NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.*

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

#### Details of the Building/Premises.


01.	Name and Address of the Applicant	The President Shri Shirdi Sai Shikshan Samsthe, Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District.
02.	Name and Address of the Premises	Shri Shirdi Sai Shikshan Samsthe, Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District.
03.	Name and Address of the Building Owner	The President Smt. Vidya S Wali Sidrameshwar Colony, Mudhol, Mudhol Taluk, Bagalkot District.
04.	Number of Building	01
05.	Number of Floors	Ground & 1 <sup>st</sup> Floor
06.	<b>Floor-wise details of Occupancy:-</b>	
	Ground Floor	Class Room-10, Principal Cabin-01, Admin Room-01 & Laboratory-03.

27/03/23

	1 <sup>st</sup> Floor	Class Room-11, Library-01 & O.T.S. Room-01
	2 <sup>nd</sup> Floor	Under Construction
07.	Height of the building	06.40 Mtr
08.	Site area	13527.08 Sq Mtr.
09.	<b>Built-up area of each floor:-</b>	
	Ground Floor	1254.68 Sq Mtr.
	1 <sup>st</sup> floor	1226.62 Sq Mtr.
10.	Total Built-up area	<b>2481.30 Sq Mtr.</b>
11.	<b>Surrounding properties:-</b>	
	East	Open Ground
	West	Road
	North	Agriculture land
	South	09.00 mtr wide Canal Road
12.	<b>Open Space all around the building</b>	
	East	06.00 Mtr
	West	05.00 Mtr
	North	05.00 Mtr
	South	06.00 Mtr
Allowed Setbacks ( open space) should be maintained free from further obstruction/construction.		

**B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-**

Sl.No (01)	Details (02)	Existing (03)	Recommendations (04)												
01.	Accessibility to the premises	The premises is accessible from 20.00 Mtr wide road on the Western Side	Adequate												
02.	Number of Entrances	One entrance of 06.00 mtr wide.	Adequate												
03.	Number of Staircase	<table border="1"> <tr> <td>No of staircase</td> <td>02 nos both are equal Measures</td> </tr> <tr> <td>Width of the staircase</td> <td>01.00 mtr</td> </tr> <tr> <td>Width of threads</td> <td>0.30 mtr</td> </tr> <tr> <td>Height of risers</td> <td>0.15 mtr</td> </tr> <tr> <td>No of risers per flight</td> <td>12</td> </tr> <tr> <td>Height of the hand drill.</td> <td>01.00 mtr</td> </tr> </table>	No of staircase	02 nos both are equal Measures	Width of the staircase	01.00 mtr	Width of threads	0.30 mtr	Height of risers	0.15 mtr	No of risers per flight	12	Height of the hand drill.	01.00 mtr	Complied
No of staircase	02 nos both are equal Measures														
Width of the staircase	01.00 mtr														
Width of threads	0.30 mtr														
Height of risers	0.15 mtr														
No of risers per flight	12														
Height of the hand drill.	01.00 mtr														
	Portable Extinguishers	<p>08 nos. of 6 Kg capacity ABC type extinguishers and 01 nos. of 2 Kg capacity CO2 type extinguisher has been provided.</p> <p>All the extinguishers suggested are BIS markings and are located at an easily accessible position without obstructing the normal passage.</p>	Complied												
05.	Hose reel hose system	04 nos. of hose reel hose has been (two in a each floor) provided. The	Complied												

  
28/03/03

		hose reel hose of min 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size. The hose reel hose is connected at staircase landing of the building.	
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	The system has been connected to booster pump of 450 LPM capacity has been provided. Further the system also has been connected to alternative source of power supply.	Complied
07.	Diesel Generator	01 no.of 15KVA capacity generator has been provided.	Complied
08.	Terrace Tank	01 no of 5000 Ltrs capacity overhead tank has been Provided.	Adequate
09.	Escape routes	Direction in which the the students/teachers have to move in the event of emergency have been indicated in the corridor/passage as a guide during evacuation .	Complied.
10.	Fire Order ( Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed along with the telephone numbers of Athani Fire station i.e 08289-251740, 101 & 080-22971550, 22971500, 22971600 the telephone nos nearest ambulance services and police station.	Complied
11.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages and is displayed inside the entry/exit of the each floor.	Complied
12.	Fire Siren	A fire siren has been installed in the premises to inform the students/teachers in case of a fire emergency and evacuate the area.	Complied
13.	Nominate One Fire Nodal Officer	Mr.Adivappa M parit Mr.Ravi M Palabhavi Are nominated as fire nodal officers	Complied
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.



15. **Fire Precautionary Measures**

- A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.  
B:- Accumulation of combustible waste in and around the premises should be avoided.  
C:- The Exit ways shall be always kept clear without any obstruction.  
D:- Liquefied petroleum gas should not be stored in the building.  
E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.  
F:- During the class hours the class room door shall not be locked from inside to out side.  
G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordination with the fire services department.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "NOC" to **Shri Shirdi Sai Shikshan Samsthe's, Institution, Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District.** As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at Training Centre R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.

This "NOC" is valid for only one year from the date of issue and is renewable.



Yours Faithfully

  
District Fire Officer  
Karnataka State Fire And Emergency Services  
Belagavi-01.

Copy to,  
Fire Station Officer, Athani.



**FIRE SAFETY CERTIFICATE**

No: 300/NOC/DFO/BELAGAVI/22-2023

Date: 27-03-2023

Certified that the **Shri Shirdi Sai Shikshan Samsthe's, Institution, Kokatnur Road, Saigiri, Athani, Athani Taluk, Belagavi District**. Comprised of **Ground & One Upper Floor** Owned/Occupied by **Shri Shirdi Sai Shikshan Samsthe's, Institution**, have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the **Fire Station Officer, Athani Fire Service** on **24-03-2023** in the presence of The President, **Smt. Vidya S Wali** and that the Building/Premises is fit for occupancy upto classes **X<sup>th</sup>** with effect from **27-03-2023** for a period of **One Year** in accordance with rule and subject to compliance of specific conditions as appended:-

1. Maintenance of all fire fighting installations periodically

Issued on 27-03-2023 at Belagavi, by

Strike out whichever is not applicable.



To,

The President  
Shri Shirdi Sai  
Shikshan Samsthe,  
Kokatnur Road, Saigiri, Athani,  
Athani Taluk, Belagavi District.

Signature with Seal

Name

Designation

Name &amp; Address

of Department/Office

Karnataka State Fire And Emergency Services

Belagavi-01.

: S.S.Nilgar  
: District Fire Officer: Office of the District Fire Officer  
Karnataka State Fire & Emergency  
Services, Khanapur Road, Near  
Goaves Circle, Belagavi-590001.**ENDORSEMENT**

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(Name and Designation of the authorized signatory)

\*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with original vernacular certificate as a single pdf.